

October 20, 2021

eGauge Systems LLC
1644 Conestoga St. Suite 2
Boulder, CO 80301

Dear David Mosberger,

Enclosed is the limited Meter Accuracy test report for testing of the eGauge Systems LLC, EG4215 meter, ECS20-200 CTs to the requirements of ANSI C12.1-2014 for Electric Meters, Code for Electricity Metering and ANSI C12.20-2015 for Electricity Meters – 0.1, 0.2 and 0.5 Accuracy Classes.

Thank you for using the services of Eurofins Electrical and Electronic Testing NA, Inc. If you have any questions regarding these results or if Eurofins Electrical and Electronic Testing NA, Inc. can be of further service to you, please feel free to contact me.

Sincerely yours,



Michelle Tawmging
Documentation Department
Eurofins Electrical and Electronic Testing NA, Inc.

Reference: (eGauge Systems LLC\ TEL111846-ANSI Rev. 1)



Certificates and reports shall not be reproduced except in full, without the written permission of Eurofins Electrical and Electronic Testing NA, Inc. While use of the A2LA logo in this report reflects Eurofins Electrical and Electronic Testing NA, Inc. accreditation under these programs, the report must not be used by the client to claim product certification, approval, or endorsement by A2LA, or any agency of the Federal Government. This letter of transmittal is not a part of the attached report.

Eurofins Electrical and Electronic Testing NA, Inc. (Eurofins E&E North America) is part of the Eurofins Electrical & Electronics (E&E) global compliance network.

Test Report

For the

**eGauge Systems LLC
EG4215 meter, ECS20-200 CTs**

Tested under

**ANSI C12.1
ANSI C12.20**

Report: TEL111846-ANSI Rev. 1

October 20, 2021

Prepared for:

**eGauge Systems LLC
1644 Conestoga St. Suite 2
Boulder, CO 80301**

**Prepared by:
Eurofins Electrical and Electronic Testing NA, Inc.
914 W. Patapsco Ave
Baltimore, MD 21230**

Test Report

For the

eGauge Systems LLC
EG4215 meter, ECS20-200 CTs

Tested under

ANSI C12.1
ANSI C12.20

Report: TEL111846-ANSI Rev. 1



Michael DeVilbiss
Meter Accuracy Lab



Michelle Tawmging
Documentation Department

Engineering Statement: The measurements shown in this report were made in accordance with the procedures indicated, and the emissions from this equipment were found to be **within** the limits applicable. I assume full responsibility for the accuracy and completeness of these measurements, and for the qualifications of all persons taking them. It is further stated that upon the basis of the measurements made, the equipment tested is capable of operation in accordance with the requirements of the customer supplied test plan.



Jim Reed
Meter Accuracy Lab

Report Status Sheet

Revision	Report Date	Reason for Revision
∅	May 28, 2021	Initial Issue.
1	October 20, 2021	Updated Model(s) Tested and Model(s) Covered throughout.

Table of Contents

1.0 Requirement Summary	1
2.0 Equipment Configuration	2
2.1 Overview	2
2.2 Test Site	2
2.3 Description of Test Sample	2
2.4 Equipment Configuration	3
2.5 Support Equipment	3
2.6 Wireless Modules	3
2.7 Isolating Paths	4
2.8 Mode of Operation	4
2.9 Method of Monitoring EUT Operation	4
2.10 Modifications	4
Modifications to EUT	4
Modifications to Test Standard	4
2.11 Disposition of EUT	4
3.0 Performance Requirements – Accuracy Tests, Internal Influences	5
3.1 Test No. 1: No Load	5
3.2 Test No. 2: Starting Load	9
3.3 Test No. 3: Load Performance	12
3.4 Test No. 4: Effect of Variation of Power Factor	21
3.5 Test No. 6: Effect of Variation of Frequency	31
3.6 Test No. 11: Effect of Internal Heating	40
3.7 Test No. 13: Stability of Performance	58
4.0 Performance Requirements – Accuracy Tests, External Influences	74
4.1 Test No. 19: Effects of Variation of Ambient Temperature	74
5.0 Test Equipment	91

List of Tables

Table 1: Summary of ANSI C12.1-2014 and ANSI C12.20-2015 Test Results.....	1
Table 2: Equipment Configuration	3
Table 3: Support Equipment.....	3
Table 4: Wireless Modules	3
Table 5: Isolating Paths	4
Table 6: SN 2101080002 - Test 1 - No Load C12-20 - TEL TDS-226 JR 4-25-16.....	5
Table 7: SN 2101080004 - Test 1 - No Load C12-20 - TEL TDS-226 JR 4-25-16.....	6
Table 8: SN 2101080005 - Test 1 - No Load C12-20 - TEL TDS-226 JR 4-25-16.....	7
Table 9: Starting Load Test	9
Table 10: Test 2 - Starting Load C12-20 - TEL TDS-227 JR 4-25-16.....	10
Table 11: Load Performance Tests	12
Table 12: SN 2101080002 - CT# 0 - Port 1 - Test 3 (0.5 class) - Class 200 Load Performance C12-20.....	12
Table 13: SN 2101080002 - CT# 1 - Port 2 - Test 3 (0.5 class) - Class 200 Load Performance C12-20.....	13
Table 14: SN 2101080002 - CT# 2 - Port 3 - Test 3 (0.5 class) - Class 200 Load Performance C12-20.....	13
Table 15: SN 2101080002 - CT# 3 - Port 4 - Test 3 (0.5 class) - Class 200 Load Performance C12-20.....	14
Table 16: SN 2101080002 - CT# 4 - Port 5 - Test 3 (0.5 class) - Class 200 Load Performance C12-20.....	14
Table 17: SN 2101080004 - CT# 5 - Port 1 - Test 3 (0.5 class) - Class 200 Load Performance C12-20.....	15
Table 18: SN 2101080004 - CT# 6 - Port 2 - Test 3 (0.5 class) - Class 200 Load Performance C12-20.....	15
Table 19: SN 2101080004 - CT# 7 - Port 3 - Test 3 (0.5 class) - Class 200 Load Performance C12-20.....	16
Table 20: SN 2101080004 - CT# 8 - Port 4 - Test 3 (0.5 class) - Class 200 Load Performance C12-20.....	16
Table 21: SN 2101080004 - CT# 9 - Port 5 - Test 3 (0.5 class) - Class 200 Load Performance C12-20.....	17
Table 22: SN 2101080005 - CT# 10 - Port 1 - Test 3 (0.5 class) - Class 200 Load Performance C12-20.....	17
Table 23: SN 2101080005 - CT# 11 - Port 2 - Test 3 (0.5 class) - Class 200 Load Performance C12-2.....	18
Table 24: SN 2101080005 - CT# 12 - Port 3 - Test 3 (0.5 class) - Class 200 Load Performance C12-2.....	18
Table 25: SN 2101080005 - CT# 14 - Port 4 - Test 3 (0.5 class) - Class 200 Load Performance C12-2.....	19
Table 26: SN 2101080005 - CT# 15 - Port 5 - Test 3 (0.5 class) - Class 200 Load Performance C12-2.....	19
Table 27: Effect of Variation of Power Factor for Single-Element Meters.....	21
Table 28: Effect of Variation of Power Factor for Two-Element Meters.....	21
Table 29: Effect of Variation of Power Factor for Three-Element Meters.....	22
Table 30: SN 2101080002 - CT# 0 - Port 1 - Test 4 (5.5.4.4.1) 0.5 class - Class 200 Power Factor C12-20.....	22
Table 31: SN 2101080002 - CT# 1 - Port 2 - Test 4 (5.5.4.4.1) 0.5 class - Class 200 Power Factor C12-2.....	23
Table 32: SN 2101080002 - CT# 2 - Port 3 - Test 4 (5.5.4.4.1) 0.5 class - Class 200 Power Factor C12-2.....	23
Table 33: SN 2101080002 - CT# 3 - Port 4 - Test 4 (5.5.4.4.1) 0.5 class - Class 200 Power Factor C12-2.....	24
Table 34: SN 2101080002 - CT# 4 - Port 5 - Test 4 (5.5.4.4.1) 0.5 class - Class 200 Power Factor C12.....	24
Table 35: SN 2101080004 - CT# 5 - Port 1 - Test 4 (5.5.4.4.1) 0.5 class - Class 200 Power Factor C12-20.....	25
Table 36: SN 2101080004 - CT# 6 - Port 2 - Test 4 (5.5.4.4.1) 0.5 class - Class 200 Power Factor C12-20.....	25
Table 37: SN 2101080004 - CT# 7 - Port 3 - Test 4 (5.5.4.4.1) 0.5 class - Class 200 Power Factor C12-20.....	26
Table 38: SN 2101080004 - CT# 8 - Port 4 - Test 4 (5.5.4.4.1) 0.5 class - Class 200 Power Factor C12-20.....	26
Table 39: SN 2101080004 - CT# 9 - Port 5 - Test 4 (5.5.4.4.1) 0.5 class - Class 200 Power Factor C12-20.....	27
Table 40: SN 2101080005 - CT# 10 - Port 1 - Test 4 (5.5.4.4.1) 0.5 class - Class 200 Power Factor C12-20.....	27
Table 41: SN 2101080005 - CT# 11 - Port 2 - Test 4 (5.5.4.4.1) 0.5 class - Class 200 Power Factor C12.....	28
Table 42: SN 2101080005 - CT# 12 - Port 3 - Test 4 (5.5.4.4.1) 0.5 class - Class 200 Power Factor C12.....	28
Table 43: SN 2101080005 - CT# 14 - Port 4 - Test 4 (5.5.4.4.1) 0.5 class - Class 200 Power Factor C12.....	29
Table 44: SN 2101080005 - CT# 15 - Port 5 - Test 4 (5.5.4.4.1) 0.5 class - Class 200 Power Factor C12.....	29
Table 45: Effect of Variation of Frequency.....	31
Table 46: SN 2101080002 - CT# 0 - Port 1 - Test 6 (0.5 class) - Class 200 Var of Frequency C12-20 - TEL TDS-300 JR 1-20-15.....	31
Table 47: SN 2101080002 - CT# 1 - Port 2 - Test 6 (0.5 class) - Class 200 Var of Frequency C12-20 - TEL TDS-300 JR.....	32

Table 48: SN 2101080002 - CT# 2 - Port 3 - Test 6 (0.5 class) - Class 200 Var of Frequency C12-20 - TEL TDS-300 JR.....	32
Table 49: SN 2101080002 - CT# 3 - Port 4 - Test 6 (0.5 class) - Class 200 Var of Frequency C12-20 - TEL TDS-300 JR.....	33
Table 50: SN 2101080002 - CT# 4 - Port 5 - Test 6 (0.5 class) - Class 200 Var of Frequency C12-20 - TEL TDS-300 JR.....	33
Table 51: SN 2101080004 - CT# 5 - Port 1 - Test 6 (0.5 class) - Class 200 Var of Frequency C12-20 - TEL TDS-300 JR 1-20-15.....	34
Table 52: SN 2101080004 - CT# 6 - Port 2 - Test 6 (0.5 class) - Class 200 Var of Frequency C12-20 - TEL TDS-300 JR.....	34
Table 53: SN 2101080004 - CT# 7 - Port 3 - Test 6 (0.5 class) - Class 200 Var of Frequency C12-20 - TEL TDS-300 JR.....	35
Table 54: SN 2101080004 - CT# 8 - Port 4 - Test 6 (0.5 class) - Class 200 Var of Frequency C12-20 - TEL TDS-300 JR.....	35
Table 55: SN 2101080004 - CT# 9 - Port 5 - Test 6 (0.5 class) - Class 200 Var of Frequency C12-20 - TEL TDS-300 JR.....	36
Table 56: SN 2101080005 - CT# 10 - Port 1 - Test 6 (0.5 class) - Class 200 Var of Frequency C12-20 - TEL TDS-300 JR 1-20-15.....	36
Table 57: SN 2101080005 - CT# 11 - Port 2 - Test 6 (0.5 class) - Class 200 Var of Frequency C12-20 - TEL TDS-300 JR.....	37
Table 58: SN 2101080005 - CT# 12 - Port 3 - Test 6 (0.5 class) - Class 200 Var of Frequency C12-20 - TEL TDS-300 JR.....	37
Table 59: SN 2101080005 - CT# 14 - Port 4 - Test 6 (0.5 class) - Class 200 Var of Frequency C12-20 - TEL TDS-300 JR.....	38
Table 60: SN 2101080005 - CT# 15 - Port 5 - Test 6 (0.5 class) - Class 200 Var of Frequency C12-20 - TEL TDS-300 JR.....	38
Table 61: Effect of Internal Heating for Current Classes 2, 10, and 20.....	40
Table 62: Effect of Internal Heating for Current Classes 100, 200, and 320.....	41
Table 63: SN 2101080002 CT# 0 - Port 1 - Test 11 (0.5 class) - Class 200 Internal Heating C12-20.....	42
Table 64: SN 2101080002 CT# 1 - Port 2 - Test 11 (0.5 class) - Class 200 Internal Heating C12-20.....	43
Table 65: SN 2101080002 CT# 2 - Port 3 - Test 11 (0.5 class) - Class 200 Internal Heating C12-20.....	44
Table 66: SN 2101080002 CT# 3 - Port 4 - Test 11 (0.5 class) - Class 200 Internal Heating C12-20.....	45
Table 67: SN 2101080002 CT# 4 - Port 5 - Test 11 (0.5 class) - Class 200 Internal Heating C12-20.....	46
Table 68: SN 2101080004 CT# 5 - Port 1 - Test 11 (0.5 class) - Class 200 Internal Heating C12-20.....	47
Table 69: SN 2101080004 CT# 6 - Port 2 - Test 11 (0.5 class) - Class 200 Internal Heating C12-20.....	48
Table 70: SN 2101080004 CT# 7 - Port 3 - Test 11 (0.5 class) - Class 200 Internal Heating C12-20.....	49
Table 71: SN 2101080004 CT# 8 - Port 4 - Test 11 (0.5 class) - Class 200 Internal Heating C12-20.....	50
Table 72: SN 2101080004 CT# 9 - Port 5 - Test 11 (0.5 class) - Class 200 Internal Heating C12-20.....	51
Table 73: SN 2101080005 CT# 10 - Port 1 - Test 11 (0.5 class) - Class 200 Internal Heating C12-20.....	52
Table 74: SN 2101080005 CT# 11 - Port 2 - Test 11 (0.5 class) - Class 200 Internal Heating C12-20.....	53
Table 75: SN 2101080005 CT# 12 - Port 3 - Test 11 (0.5 class) - Class 200 Internal Heating C12-20.....	54
Table 76: SN 2101080005 CT# 14 - Port 4 - Test 11 (0.5 class) - Class 200 Internal Heating C12-20.....	55
Table 77: SN 2101080005 CT# 15 - Port 5 - Test 11 (0.5 class) - Class 200 Internal Heating C12-20.....	56
Table 78: SN 2101080002 - CT# 0 - Port 1 - Test 13 (0.5 class) - Stability of Performance C12-20 - TEL.....	58
Table 79: SN 2101080002 - CT# 1 - Port 2 - Test 13 (0.5 class) - Stability of Performance C12-20 - TEL.....	59
Table 80: SN 2101080002 - CT# 2 - Port 3 - Test 13 (0.5 class) - Stability of Performance C12-20 - TEL.....	60
Table 81: SN 2101080002 - CT# 3 - Port 4 - Test 13 (0.5 class) - Stability of Performance C12-20 - TEL.....	61
Table 82: SN 2101080002 - CT# 4 - Port 5 - Test 13 (0.5 class) - Stability of Performance C12-20 - TEL.....	62
Table 83: SN 2101080004 - CT# 5 - Port 1 - Test 13 (0.5 class) - Stability of Performance C12-20 - TEL.....	63
Table 84: SN 2101080004 - CT# 6 - Port 2 - Test 13 (0.5 class) - Stability of Performance C12-20 - TEL.....	64
Table 85: SN 2101080004 - CT# 7 - Port 3 - Test 13 (0.5 class) - Stability of Performance C12-20 - TEL.....	65
Table 86: SN 2101080004 - CT# 8 - Port 4 - Test 13 (0.5 class) - Stability of Performance C12-20 - TEL.....	66
Table 87: SN 2101080004 - CT# 9 - Port 5 - Test 13 (0.5 class) - Stability of Performance C12-20 - TEL.....	67

Table 88: SN 2101080005 - CT# 10 - Port 1 - Test 13 (0.5 class) - Stability of Performance C12-20 - TEL.....	68
Table 89: SN 2101080005 - CT# 11 - Port 2 - Test 13 (0.5 class) - Stability of Performance C12-20 - TEL.....	69
Table 90: SN 2101080005 - CT# 12 - Port 3 - Test 13 (0.5 class) - Stability of Performance C12-20 - TEL.....	70
Table 91: SN 2101080005 - CT# 14 - Port 4 - Test 13 (0.5 class) - Stability of Performance C12-20 - TEL.....	71
Table 92: SN 2101080005 - CT# 15 - Port 5 - Test 13 (0.5 class) - Stability of Performance C12-20 - TEL.....	72
Table 93: Effects of Variation of Ambient Temperature	75
Table 94: SN 2101080002 - CT# 0 - Port 1 - Test 19 (0.5 class) - Class 200 Ambient Temp C12-20	76
Table 95: SN 2101080002 - CT# 1 - Port 2 - Test 19 (0.5 class) - Class 200 Ambient Temp C12-20	77
Table 96: SN 2101080002 - CT# 2 - Port 3 - Test 19 (0.5 class) - Class 200 Ambient Temp C12-20	78
Table 97: SN 2101080002 - CT# 3 - Port 4 - Test 19 (0.5 class) - Class 200 Ambient Temp C12-20	79
Table 98: SN 2101080002 - CT# 4 - Port 5 - Test 19 (0.5 class) - Class 200 Ambient Temp C12-20	80
Table 99: : SN 2101080004 - CT# 5 - Port 1 - Test 19 (0.5 class) - Class 200 Ambient Temp C12-20	81
Table 100: : SN 2101080004 - CT# 6 - Port 2 - Test 19 (0.5 class) - Class 200 Ambient Temp C12-20	82
Table 101: SN 2101080004 - CT# 7 - Port 3 - Test 19 (0.5 class) - Class 200 Ambient Temp C12-20	83
Table 102: SN 2101080004 - CT# 8 - Port 4 - Test 19 (0.5 class) - Class 200 Ambient Temp C12-20	84
Table 103: SN 2101080004 - CT# 9 - Port 5 - Test 19 (0.5 class) - Class 200 Ambient Temp C12-20	85
Table 104: SN 2101080005 - CT# 10 - Port 1 - Test 19 (0.5 class) - Class 200 Ambient Temp C12-20	86
Table 105: SN 2101080005 - CT# 11 - Port 2 - Test 19 (0.5 class) - Class 200 Ambient Temp C12-20	87
Table 106: SN 2101080005 - CT# 12 - Port 3 - Test 19 (0.5 class) - Class 200 Ambient Temp C12-20	88
Table 107: SN 2101080005 - CT# 14 - Port 4 - Test 19 (0.5 class) - Class 200 Ambient Temp C12-20	89
Table 108: SN 2101080005 - CT# 15 - Port 5 - Test 19 (0.5 class) - Class 200 Ambient Temp C12-20	90
Table 109: Test Equipment.....	92

List of Figures

Figure 1: No Load Test Setup.....	8
Figure 2: Starting Load Test Setup	11
Figure 3: Load Performance Test Setup	20
Figure 4: Power Factor Test Setup	30
Figure 5: Effect of Variation of Frequency Test Setup.....	39
Figure 6: Effect of Internal Heating Test Setup	57
Figure 7: Stability of Performance Test Setup.....	73
Figure 8: Ambient Temperature Test Setup	90

List of Terms and Abbreviations

AC	Alternating Current
ACF	Antenna Correction Factor
Cal	Calibration
d	Measurement Distance
dB	decibels
dBμA	decibels above one micro Amp
dBμV	decibels above one micro Volt
dBμA/m	decibels above one micro Amp per meter
dBμV/m	decibels above one micro Volt per meter
DC	Direct Current
E	Electric Field
DSL	Digital Subscriber Line
ESD	Electrostatic Discharge
EUT	Equipment Under Test
f	Frequency
GRP	Ground Reference Plane
H	Magnetic Field
HCP	Horizontal Coupling Plane
Hz	Hertz
IEC	International Electrotechnical Commission
kHz	kilo Hertz
kPa	kilo Pascal
kV	kilo Volt
LISN	Line Impedance Stabilization Network
MHz	Mega Hertz
μH	micro Henry
μF	microfarad
μs	micro seconds
PRF	Pulse Repetition Frequency
RF	Radio Frequency
RMS	Root-Mean-Square
TWT	Traveling Wave Tube
V/m	Volts per meter
VCP	Vertical Coupling Plane

1.0 Requirement Summary

An evaluation to determine compliance of the eGauge Systems LLC EG4215 meter, ECS20-200 CTs was performed on a sample of the equipment for the purpose of demonstrating compliance with ANSI 12.20-2015 for Electricity Meters - 0.2 and 0.5 Accuracy Classes.

5.5.4.1 - No Load - Test #1		Completed
5.5.4.1 - No Load - Test #1	SN 2101080002 - CL200 - 277V L-N - CT#s 0, 1, 2, 3, 4	Compliant
	SN 2101080004 - CL200 - 277V L-N - CT#s 5, 6, 7, 8, 9	Compliant
	SN 2101080005 - CL200 - 277V L-N - CT#s 10, 11, 12, 14, 15	Compliant
5.5.4.2 - Starting Load - Test #2		Completed
5.5.4.2 - Starting Load - Test #2	SN 2101080002 - CL200 - 277V L-N - CT#s 0, 1, 2, 3, 4	Compliant
	SN 2101080004 - CL200 - 277V L-N - CT#s 5, 6, 7, 8, 9	Compliant
	SN 2101080005 - CL200 - 277V L-N - CT#s 10, 11, 12, 14, 15	Compliant
5.5.4.3 - Load Performance - Test #3		Completed
5.5.4.3 - Load Performance - Test #3	SN 2101080002 - CL200 - 277V L-N - CT#s 0, 1, 2, 3, 4	Compliant
	SN 2101080004 - CL200 - 277V L-N - CT#s 5, 6, 7, 8, 9	Compliant
	SN 2101080005 - CL200 - 277V L-N - CT#s 10, 11, 12, 14, 15	Compliant
5.5.4.4 - Variation of Power Factor - Test #4		Completed
5.5.4.4 - Variation of Power Factor - Test #4	SN 2101080002 - CL200 - 277V L-N - CT#s 0, 1, 2, 3, 4	Compliant
	SN 2101080004 - CL200 - 277V L-N - CT#s 5, 6, 7, 8, 9	Compliant
	SN 2101080005 - CL200 - 277V L-N - CT#s 10, 11, 12, 14, 15	Compliant
5.5.4.6 - Variation of Frequency - Test #6		Completed
5.5.4.6 - Variation of Frequency - Test #6	SN 2101080002 - CL200 - 277V L-N - CT#s 0, 1, 2, 3, 4	Compliant
	SN 2101080004 - CL200 - 277V L-N - CT#s 5, 6, 7, 8, 9	Compliant
	SN 2101080005 - CL200 - 277V L-N - CT#s 10, 11, 12, 14, 15	Compliant
5.5.4.11 - Effect of Internal Heating - Test #11		Completed
5.5.4.11 - Effect of Internal Heating - Test #11	SN 2101080002 - CL200 - 277V L-N - CT#s 0, 1, 2, 3, 4	Compliant
	SN 2101080004 - CL200 - 277V L-N - CT#s 5, 6, 7, 8, 9	Compliant
	SN 2101080005 - CL200 - 277V L-N - CT#s 10, 11, 12, 14, 15	Compliant
5.5.4.13 - Stability of Performance - Test #13		Completed
5.5.4.13 - Stability of Performance - Test #13	SN 2101080002 - CL200 - 277V L-N - CT#s 0, 1, 2, 3, 4	Compliant
	SN 2101080004 - CL200 - 277V L-N - CT#s 5, 6, 7, 8, 9	Compliant
	SN 2101080005 - CL200 - 277V L-N - CT#s 10, 11, 12, 14, 15	Compliant
5.5.5.6 - Variation of Ambient Temperature - Test #19		Completed
5.5.5.6 - Variation of Ambient Temperature - Test #19	SN 2101080002 - CL200 - 277V L-N - CT#s 0, 1, 2, 3, 4	Compliant
	SN 2101080004 - CL200 - 277V L-N - CT#s 5, 6, 7, 8, 9	Compliant
	SN 2101080005 - CL200 - 277V L-N - CT#s 10, 11, 12, 14, 15	Compliant

Table 1: Summary of ANSI C12.1-2014 and ANSI C12.20-2015 Test Results

2.0 Equipment Configuration

2.1 Overview

The purpose of this series of tests was to verify compliance of the eGauge Systems LLC EG4215 meter, ECS20-200 CTs (referred to as EUT hereafter) with the limits of ANSI C12.1-2014 for Electric Meters, Code for Electricity Metering and ANSI C12.20-2015 for Electricity Meters - 0.2 and 0.5 Accuracy Classes.

Model(s) Tested:	EG4215 meter, ECS20-200 CTs
Model(s) Covered:	Meter models EG4000 through EG4999 (including EG4015, EG4030, EG4115, EG4130, EG4215, EG4230), ECS20-200 CTs
EUT Specifications:	Class: See Equipment Configuration Table
Analysis:	The results obtained relate only to the item(s) tested.
Ambient Lab Test Conditions:	Temperature: 23° C±2°C
	Relative Humidity: 30-60%
	Atmospheric Pressure: 860-1060 mbar
Evaluated by:	Michael DeVilbiss

2.2 Test Site

All testing was performed at Eurofins Electrical and Electronic Testing NA, Inc., 914 West Patapsco Ave., Baltimore MD 21230. All equipment used in making physical determinations is accurate and bears recent traceability to the National Institute of Standards and Technology.

2.3 Description of Test Sample

The Equipment Under Test (EUT) is an EG4215 meter, ECS20-200 CTs. The device is an electric energy meter with built-in data-logging and networking capabilities. Commonly, the device is used to monitor circuit-level electricity consumption at a site and/or electricity produced by renewable energy systems. More generally, the meter can be used to track production/consumption on up to 30 different circuits.

2.4 Equipment Configuration

All equipment incorporated as part of the EUT is included in the following list.

Distribution Circuit Configuration:(1-Phase 2-Wire;1-Phase 3-Wire;3-Wire Network;3-Wire 3-Phase Delta;4-Wire 3-Phase Delta;4-Wire 3-Phase Wye)

Voltage: (L-N and/or L-L voltages per configuration)

Test Amps: Recommended TA points per CL - CL2: 0.25; CL10: 2.5; CL20: 2.5; CL100: 15; CL200: 30; CL320: 50

Meter Form	Distribution Circuit Configuration	Voltage L-N	Voltage L-L	Current Class	Test Amps	Accuracy Class	Model/ Part Number	Serial Number	Firmware Revision	External CT or Sensor
	4-Wire 3-Phase	277	480	200	30	.5	EG4215	2101080002	4.1.7beta4	5x ECS20-200
	4-Wire 3-Phase	277	480	200	30	.5	EG4215	2101080004	4.1.7beta4	5x ECS20-200
	4-Wire 3-Phase	277	480	200	30	.5	EG4215	2101080005	4.1.7beta4	5x ECS20-200

Table 2: Equipment Configuration

2.5 Support Equipment

Support equipment necessary for the operation and testing of the EUT is included in the following list.

Name	Manufacturer	Model No.	Serial No.	Calibration Data
Laptop	ASUS	C100P	05NLCX047015209	-
Ethernet dongle	Apple	A1277	825-7579-A	-
Ethernet switch	Netgear	FS105	1D52423U52CA3	-
Power supply	Netgear	MU08A9075100-A1	-	-
Power supply	ASUS	AD2055320	-	-
Ethernet cables	-	-	-	-

Table 3: Support Equipment

2.6 Wireless Modules

Manufacturer	Model No.	Revision No.	FCC ID No.
Microchip Technology Inc	ATWILC1000-MR110UB	-	2ADHKATWILC1000U
Microchip Technology Inc	ATWILC1000-MR110UB	-	2ADHKATWILC1000U

Table 4: Wireless Modules

2.7 Isolating Paths

Voltage Line 1 & Current Circuit A to Earth Ground
Voltage Line 2 & Current Circuit B to Earth Ground
Voltage Line 3 & Current Circuit C to Earth Ground
Neutral to Earth Ground
Current Circuit A to Neutral
Current Circuit B to Neutral
Current Circuit C to Neutral
Current Circuit A to Current Circuit B
Current Circuit A to Current Circuit C
Current Circuit B to Current Circuit C
Voltage Line 1 & Current Circuit A to Neutral
Voltage Line 2 & Current Circuit B to Neutral
Voltage Line 3 & Current Circuit C to Neutral
Voltage Line 1 & Current Circuit A to Voltage Line 2 & Current Circuit B
Voltage Line 1 & Current Circuit A to Voltage Line 3 & Current Circuit C
Voltage Line 2 & Current Circuit B to Voltage Line 3 & Current Circuit C

Table 5: Isolating Paths

2.8 Mode of Operation

During normal operation, the EUT's LCD should show a heartbeat symbol in the upper-left corner that flashes once per second. The display should also cycle through the configured registers at about 10 seconds per register. The EUT's web server should be accessible via its IP address. A blank or frozen LCD would indicate a failure.

2.9 Method of Monitoring EUT Operation

The metering web page at <http://IPADDR/meter.html> updates once a second if the meter, web server, and communication operates correct and provides a convenient way to track the accumulated energy for the configured ports.\

2.10 Modifications

2.10.1 Modifications to EUT

No Modifications were made to the EUT.

2.10.2 Modifications to Test Standard

No Modifications were made to the test standard.

2.11 Disposition of EUT

The test sample including all support equipment submitted to the Electro-Magnetic Compatibility Lab for testing was returned to eGauge Systems LLC upon completion of testing.