

Supported CT types

The EG30xx and EG4xxx are Listed Devices, certified to be used with CTs that have the following specifications: UR and CSA, 0.333Vrms output at rated current, and 600V insulation. While any CT with these specifications can be safely attached, only CTs listed in section B.6 of the [EG30xx Owner's Manual](#) and section B.6 of the [EG4xxx Owner's Manual](#) have been evaluated by eGauge Systems to ensure correct performance and accuracy.

As a general rule, any CT used with an older model of eGauge should be automatically supported by a newer model. For example, the CTs used with an eGauge2 should be supported by an EG30xx or EG4xxx. Moving from a newer model of eGauge to an older model may require a [firmware update](#) to add support for certain CTs. This assumes that the CTs were originally purchased through eGauge Systems, and not a third party.

[Connecting any other hardware](#) to a CT port can damage the eGauge and will void the warranty.

Please visit kb.egauge.net for the most up-to-date documentation.