


# Three-phase High-leg delta

Three-phase high-leg delta installation measuring power coming from a power utility (grid).



## Registers:

Registers (1 of 64 in use):

Name:	Recorded value/formula:
Grid	$P = S1 \times L1 + S2 \times L2 + S3 \times L3$
<button>Add Register</button>	

Totals and Virtual Registers:

Usage	$= + \downarrow$ Grid $\times$	<button>Add Register</button>
Generation	$=$	<button>Add Register</button>
Battery	$=$	<button>Add Register</button>
Battery left	$=$	<button>Add Register</button>
<button>Add Virtual Register</button>		

## Notes:

- Wiring and configuration is identical to a standard three-phase site. The only difference is in the voltages measured on L1, L2, and L3: – L1 and L3 are 120Vac to neutral. – L2 is 208Vac to neutral.
  - It does not matter whether the high-leg is wired to L1, L2, or L3, as long as all three phases are measured.
- 

Please visit [kb.egauge.net](http://kb.egauge.net) for the most up-to-date documentation.