

# BACnet register map

The eGauge does not have a fixed BACnet register map. Instead, registers are mapped as they are created. Thus, the map for two different eGauges will differ based on the number of registers and the order they were added in. Registers are organized into groups, which are defined below.

Group 5 and Group 6 addresses may change if register configuration is modified. It is recommended to use range 0xb0000 and 0xc0000 as the addresses numbers are tied to the register ID and will always remain in that order. See [this article](#) for more information about register IDs.

Address Range	Group Description	Measured Value	See footnote
0x20000	Group 1 - The RMS voltage of the voltage-taps can be read through this group.	Voltage [V]	
0x30000	Group 2 - The RMS current measured by each sensor/CT can be read through this group.	Current [A]	1
0x50000	Group 3 - The frequency of the voltage-taps can be read through this group.	Line Frequency [Hz]	
0x60000	Group 4 contains only the object ID 0x60000 and it reports the number of seconds since BACnet daemon startup. The daemon starts after enabling BACnet support through the UI or after power-cycling.	Timestamp [s]	

0x70000	<p>Group 5 reports the register value for each register (virtual and physical). The register values are time-weighted values and hence the unit of these object IDs is equal to the unit of the corresponding object ID in Group 6, multiplied by seconds. For example, for a register recording power, the Group 6 unit would be Watts, and therefore the Group 5 unit would be Watt-seconds (i.e., Joules).</p> <p><b>DEPRECATED IN v4.0</b>, use range 0xb0000 to 0xbfff in firmware v4.0 and newer.</p>	REGVAL [various]	
0x80000	<p>Group 6 reports, for each virtual and physical register, the change in register value during the most recent one-second interval. For example, for a register recording power, the unit would be Watts, for a register recording voltage, the unit would be Volts.</p> <p><b>DEPRECATED IN v4.0</b>, use range 0xc0000 to 0xcfff in firmware v4.0 and newer.</p>	REGCHG [various]	
0x90000	Mean Voltages - mean (DC) voltages for voltage inputs	Voltage [V]	2
0xa0000	Mean Sensor Values - mean (DC) values for sensor/CT inputs	Current [A]	1, 2
0xb0000	Register values like Group 5, statically indexed by register ID	REGVAL [various]	2, 3
0xc0000	Register rate-of-change (instantaneous) values like Group 6, statically indexed by register ID	REGCHG [various]	2, 3

Footnotes:

1. Unit will be Amps for current, various for other sensors
2. Introduced in firmware v4.0
3. These addresses are tied to register ID. Group 5 and Group 6 are liable to have addresses change if register configuration is modified.

The BACnet PICS is available in the support knowledge base [here](#).

#### Additional Tips:

- Cumulative register values are found in Group 5, REGVAL. This provides time-weighted values such as kWh or amp-hours.
  - Cumulative register values may not start at zero. Thus, it is important to compare a previously received value with the current value to determine the total value change between two points in time.
- Instantaneous (rate-of-change) register values are found in Group 6, REGCHG. These provide instantaneous values such as Watts or Amps.
- The physical unit of this register depends on the quantity being recorded and can be obtained by reading the "unit" property (BACnet property 117) of the respective object id.
- The register name for a given object ID can be obtained by reading the "name" property (BACnet property 77) from the object ID.
- In Group 5 and 6, the first two object IDs will always be the **Usage** and **Generation** virtual registers. Any additional **virtual** registers come next. **Physical** registers are listed last.
- The BACnet service is enabled on the eGauge through Settings -> BACnet.

---

Revision #3

Created Mon, Feb 17, 2020 8:45 PM by [Andrew](#)

Updated Tue, Feb 16, 2021 12:02 AM by [aaron](#)